

CENWP-OD

08 December 2021

MEMORANDUM FOR THE RECORD

**TITLE** - 21DEX03 Dexter Unit Outage Ramp Rate

**PROJECT** - Dexter Dam

**NOTIFICATION DATE** - 14 December 2021

**RESPONSE DATE** - 28 December 2021

**Description of the problem**

On 07 December 2021, unit testing conducted resulted in a ramp rate deviation (-0.42 ft/hr) outside criteria (-0.2 ft/hr) detailed in the 2008 Biological Opinion (BiOp) issued by the National Marine Fisheries Service (NMFS).

**Type of event**

Ramp rate deviation, flow change of -0.42 ft/hour

**Impact on facility operation**

No impact to facility

**Expected impacts on fish**

Minimal impacts to ESA listed fish

**Comments from agencies**

No comments

Please email or call with questions or concerns.

Thank you,

Chris Walker

NWP Operations Division Fishery Section

503.808.4316

[Christopher.E.Walker@usace.army.mil](mailto:Christopher.E.Walker@usace.army.mil)